

**PERMISSION TO ENERGIZE ELECTRICAL EQUIPMENT**  
 UNDER AUTHORITY OF LAMC SECTION 93.0308  
**DEPARTMENT OF BUILDING AND SAFETY**  
**Form: PC/ELEC/Req.Mod.60**

PERMIT#		DATE:	
JOB ADDRESS:			
Tract: N/A		Block: N/A	
		Lot: N/A	
Owner:		Petitioner:	
Address:		Address:	
City	State	Zip	Phone
City	State	Zip	Phone
REQUEST		CODE SECTIONS: 93.0308 LAMC Los Angeles Electrical Code	
Permission to allow the release of permanent electrical power to the building for testing _____ prior to the issuance of a Temporary Certificate of Occupancy or Certificate of Occupancy.			
<b>JUSTIFICATION (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSARY)</b>			
To enable the testing and commissioning of Fire Life Safety, Electrical System and Equipment prior to issuance of a Certificate of Occupancy			
Owner/Petitioner Name (Print)		(Signature)	(Position)
<b>FOR CITY DEPARTMENT USE ONLY</b>			
<b>DEPARTMENT ACTION</b>			
Reviewed by: (Staff) (print) _____ Sign _____ Date _____ GRANTED _____ DENIED _____			
<b>OBTAIN THE REQUIRED INSPECTOR SIGNATURES</b>			
<i>(Return form to Electrical Inspection once all other inspectors have signed)</i>			
<b>Approved Request</b>		<b>Date</b>	<b>Signature</b>
Building			
Electrical			
Elevator			
Fire Sprinkler			
Mechanical			
Plumbing			
<b>CONDITIONS OF APPROVAL</b>			
SEC. 93.0308 TEMPORARY USE OF CURRENT			
a) The Department may permit, at its discretion, the temporary use of electrical energy for electrical wiring, before final approval thereof, whenever unnecessary hardship would otherwise result, and inspection can effectively be made after commencement of the temporary use			
b) The Department shall place those restrictions upon temporary use as necessary to insure safety, to secure compliance with all other provisions of this Code, and to facilitate inspection.			
c) No temporary use of electrical energy shall be permitted in any case where a hazard to life and property would be created.			
<b>REQUIREMENTS FOR USE OF TEMPORARY POWER</b>			
See Page 2			

## **REQUEST TO ENERGIZE PERMANENT SERVICE**

The following conditions shall be inspected and approved by the Department prior to energizing permanent services.

1. A completed departmental form requesting permission to energize permanent services prior to the issuance of a Temporary Certificate of Occupancy or Certificate of Occupancy shall be completed and submitted to and approved by the Department.
2. All service entrance conductors, feeder and branch circuit conductors shall be installed, terminated, inspected and approved by the Electrical Inspector before authorizing to energize will be granted.
3. Feeders, busways, circuit breakers, fused and unfused disconnect switches shall be locked in the open position using standard tag/out procedure.
4. The electrical equipment rooms and closets shall be completed and free from construction materials.
5. Lighting and one 120 volt 20-amp receptacle shall be provided in the main electrical rooms and energized from the permanent power.
6. Electrical equipment rooms and closets shall not be used for storage.
7. The electrical equipment room's access doors and permanent hardware including locks shall be installed. All locks and keys shall be under the exclusive control of the electrical contractor's general foreperson.
8. Manufactured signs with Red lettering on White background stating "DANGER ENERGIZED ELECTRICAL EQUIPMENT" and "ELECTRICAL ROOM AUTHORIZED PERSONEL ONLY" shall be posted at all times on doors entering, exiting: electrical equipment rooms, fire pump rooms, generator rooms, electrical closets or enclosures that have service equipment, panelboards, switchboards and Fire Pumps and motor controller centers.
9. Electrical equipment that are energized exposed in public, or in open areas shall have temporary barriers and signage to prevent accidental contact by unauthorized personal. Proper working clearance shall be maintained at all times.
10. The use of temporary power cords, lighting and equipment being supplied from the permanent service, switchboards and panelboards used for construction purposes shall require an electrical permit, inspection, and approval before being energized.