



INFORMATION BULLETIN / MECHANICAL

REFERENCE NO.: LAMC 304.3, 1105.3

DOCUMENT NO.: P/MC 2023-006

Previously Issued as: P/MC 2017-006

Effective: 01-01-2023

Revised:

ACCESS REQUIREMENTS TO MECHANICAL EQUIPMENT LOCATED ON ROOFS OF BUILDINGS

Sections 304.3 and 1105.3 exception 4 of the Los Angeles Mechanical Code address the location and accessibility of HVAC and other equipment that are installed on the roof of a building.

These Sections of the Mechanical Code are interpreted to allow the use of portable ladders for access to heating and cooling equipment and other similar motor-operated equipment, located on the roof of a building, subject to the following provisions:

1. The slope of the roof giving access to the equipment is not more than four inches measured vertically to 12 inches measured horizontally.
2. The building is an existing nonresidential type building or a new or existing residential type building, and the roof is safely accessible from the ground level by means of a 16-foot portable ladder.
3. A permanent exterior ladder on any building, regardless of building height, need not extend closer than eight feet to the finished adjoining grade level. The construction of this ladder shall comply with Section 304.3.1.2 of the Mechanical Code.

