



**Central/String Inverter Systems for One and Two Family Dwellings**

**SCOPE:** Use this plan ONLY for electrical review of utility-interactive central/string inverter systems not exceeding a combined system AC inverter output of 10kW on the roof of a single or duplex family dwelling or accessory building. The specific structural and fire requirements are covered under a separate permit. The photovoltaic system must interconnect to the load or line side of a single-phase AC service panel of 240Vac or less with a busbar rating of 225A or less. This plan is not intended for bipolar systems, hybrid systems or systems that utilize storage batteries, charge controllers, trackers or ac modules. Systems must be in compliance with current California Building Standards Codes and all applicable Los Angeles Codes. Other Articles of the California Electrical Code (CEC) shall apply as specified in 690.3.

**MANUFACTURER'S SPECIFICATION SHEETS MUST BE PROVIDED** for proposed inverters, modules, combiner/junction boxes, racking systems, and rapid shutdown system or equipment. Installation instructions for bonding and grounding equipment and rapid shutdown systems shall be provided, and local AHJs may require additional details. Listed and labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling (CEC 110.3). Equipment intended for use with PV system shall be listed for the PV application (CEC 690.4(B)).

Job Address: \_\_\_\_\_ Permit #: \_\_\_\_\_

Contractor/ Engineer Name: \_\_\_\_\_ License # and Class: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Phone Number: \_\_\_\_\_

Total # of Inverters installed: \_\_\_\_\_ (If more than one inverter, complete and attach the "Supplemental Calculation Sheets" starting on page 12 & "Load Center Calculations" on page 19 if a new load center is to be used)

Inverter 1 AC Output Power Rating: \_\_\_\_\_ Watts  
 Inverter 2 AC Output Power Rating (if applicable): \_\_\_\_\_ Watts  
 Combined Inverter Output Power Rating: \_\_\_\_\_ ≤ 10,000 Watts

**Location Ambient Temperatures:**

1) Lowest expected ambient temperature for the location ( $T_L$ ) = \_\_\_\_\_ °C Source: \_\_\_\_\_  
 Average ambient high temperature = \_\_\_\_\_ °C Source: \_\_\_\_\_

**DC Information:**

Module Manufacturer: _____		Model: _____
2) Module $V_{oc}$ (from module nameplate): _____ Volts	3) Module $I_{sc}$ (from module nameplate): _____ Amps	
4) Module dc output power under standard test conditions (STC) = _____ Watts (STC)		
<b>5) DC Module Layout</b>		
Identify each source circuit (string) for inverter 1 shown on the roof plan with a Tag (e.g. A,B,C,...)	Number of modules per source circuit for inverter 1	Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)
		Combiner 1:
		Combiner 2:
<b>Total number of source circuits for inverter 1:</b>		



**Central/String Inverter Systems for One and Two Family Dwellings**

6) **Are DC/DC Converters used?** Yes / No If "No," go to STEP#7. If "Yes," enter info below.  
 DC/DC Converter Model #: \_\_\_\_\_  
 Max DC Output Current: \_\_\_\_\_ Amps  
 Max # of DC/DC Converters in an Input Circuit: \_\_\_\_\_  
 Number of modules per DC/DC Converter \_\_\_\_\_ x Module DC Power [STEP#4] ( \_\_\_\_\_ Watts) = \_\_\_\_\_ Watts  
 Calculated power from the equation above ( \_\_\_\_\_ Watts) ≤ DC/DC Converter Max DC Input Power ( \_\_\_\_\_ Watts)  
 If DC/DC Convert input voltage is 80 volts or greater, provide listed Arc-Fault Circuit protection (CEC 690.11).

7) **Maximum System DC Voltage** – Required for all systems

Max system dc voltage shall not exceed 600 volts, inverter manufacturer’s max input voltage rating (if dc/dc converters are not used) \_\_\_\_\_ volts, or dc/dc converter max dc input voltage rating (if applicable) \_\_\_\_\_ volts. If open-circuit voltage ( $V_{oc}$  from STEP#2) temperature coefficients ( $\beta$  or  $\epsilon$ ) are provided by module manufacturer, use the calculation in **Method 1**. If  $V_{oc}$  temperature coefficient is not provided by module manufacturer, use the calculation in **Method 2**.

**Module Count:** equal to maximum number of modules in ANY source circuit [STEP#5] for systems without dc/dc converters OR equal to number of modules per dc/dc converter [STEP#6] for systems with dc/dc converters)

**Method 1:**  
 $V_{oc}$  temperature coefficient ( $\beta$ ) = \_\_\_\_\_ %/°C  
 Module Count per source circuit \_\_\_\_\_ x  $\{V_{oc} + [(T_L - 25) \times (\beta \times V_{oc}) / 100]\}$  = \_\_\_\_\_ Volts  
 If module manufacturer provides a voltage temperature coefficient ( $\epsilon$ ) in mV/°C, use the formula below.  
 $V_{oc}$  temperature coefficient ( $\epsilon$ ) = \_\_\_\_\_ mV/°C  
 Module Count per source circuit \_\_\_\_\_ x  $\{V_{oc} + [(T_L - 25) \times (\epsilon / 1000)]\}$  = \_\_\_\_\_ Volts

**Method 2:**  
 Module Count per source circuit \_\_\_\_\_ x  $V_{oc}$  \_\_\_\_\_ x  $K_T$  = \_\_\_\_\_ Volts,  
 Where  $K_T$  = \_\_\_\_\_ is a correction factor for ambient temperatures below 25°C. See Table 690.7.

8) **Maximum System DC Voltage from DC/DC Converters to Inverter** – Only required if "Yes" in STEP#6

Maximum system dc voltage shall not exceed 600 volts or inverter manufacturer’s maximum input voltage rating. If using dc/dc converters with fixed source circuit voltage (connected in series), provide the calculation in **Method 1**. If using dc/dc converters connected in series with an inverter that regulates input dc voltage, provide the calculation in **Method 2**. If using dc/dc converters with fixed unit voltage (connected in parallel), provide the calculation in **Method 3**.

**Method 1** (similar to Tigo MM-ES and Ampt Converters):  
 Max # of dc/dc converters in a source circuit [STEP#6] \_\_\_\_\_ x Max dc output voltage [STEP#6] \_\_\_\_\_ Volts = Max system dc voltage \_\_\_\_\_ Volts  
 If Max system dc voltage \_\_\_\_\_ > inverter input voltage rating ( \_\_\_\_\_ Volts) OR 600 Volts, the number of DC/DC converters in the source circuit used for the Method 1 calculation must be reduced to comply with code.

**Method 2** (similar to SolarEdge and inverters with Ampt Mode capabilities such as Kaco and Bonfiglioli):  
 Inverter max input voltage \_\_\_\_\_ Volts = Max system dc voltage \_\_\_\_\_ Volts  
 If Max system dc voltage \_\_\_\_\_ > 600 Volts, the inverter used for the Method 2 calculation must be changed to comply with code.

**Method 3** (similar to Tigo MM-EP and eIQ vBoost):  
 Max dc output voltage [STEP#6] \_\_\_\_\_ = Max system dc voltage \_\_\_\_\_ Volts  
 If Max system dc voltage \_\_\_\_\_ > inverter input voltage rating ( \_\_\_\_\_ Volts) OR 600 Volts, the dc/dc converters or inverter used for the Method 3 calculation must be changed to comply with code.



**Central/String Inverter Systems for One and Two Family Dwellings**

**9) Maximum Source Circuit Current** – If dc/dc converters are used, use 9(A). If not, use 9(B).

Calculate the maximum dc short circuit current per source circuit to allow for peak sunlight conditions:

**A. Largest number of dc/dc converters run in parallel on one source circuit:** \_\_\_\_\_ (= 1 if not run in parallel)

**Max DC Output Current [STEP#6]** \_\_\_\_\_ × dc/dc converters in parallel \_\_\_\_\_ = **Maximum Circuit Current** \_\_\_\_\_ Amps

**B. Module I<sub>sc</sub> [STEP#3]** \_\_\_\_\_ × 1.25 = **Maximum Circuit Current** \_\_\_\_\_ Amps

**10) Sizing PV Source Circuit Conductors** – Use the LARGER minimum conductor ampacity from **Method A** or **Method B** when determining required conductor size.

**Method A:**

**Minimum conductor ampacity: Maximum source circuit current [STEP#9]** \_\_\_\_\_ × 1.25 = \_\_\_\_\_ Amps

**Method B:**

**# of current-carrying conductors in raceway:** \_\_\_\_\_ **Raceway height above the roof:** \_\_\_\_\_ inches

**C<sub>F</sub>** = \_\_\_\_\_ C<sub>F</sub> is the conduit fill coefficient (refer to Table 310.15 (B)(3)(a))

**C<sub>T</sub>** = \_\_\_\_\_ C<sub>T</sub> is the coefficient dependent on the highest continuous ambient temperature (refer to Table 310.15(B)(2)(a) ) and raceway height above roof (refer to Table 310.15(B)(3)(c) if applicable)

**Minimum conductor ampacity: Maximum source circuit current [STEP#9]** \_\_\_\_\_ / (C<sub>F</sub> × C<sub>T</sub>) = \_\_\_\_\_ Amps

Using the greater current as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify source circuit conductor size (using copper 90°C-rated insulated conductors). The minimum conductor ampacity calculated from **Method A** or **Method B** shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

**Minimum Source Circuit Conductor Size** \_\_\_\_\_ AWG

(For ungrounded systems, exposed source conductors must be listed “PV Wire,” NOT USE-2, per 2013 CEC 690.35(D))

**11) Are PV source circuits combined prior to the inverter?** Yes / No

If **No**, use Single Line Diagram 1 and proceed to **STEP#13**.

If **Yes**, Is the PV source circuit combined on the roof? Yes / No

If **No**, use Single Line Diagram 2.

If **Yes**, provide a load break disconnecting means rated for the load in the combiner or within 6ft of the combiner (CEC 690.15(C)), and use single line diagram 2.

**If the source circuit voltage to combiner is 80 volts or greater, provide listed Arc-Fault Circuit protection (CEC 690.11).**

Source circuits and output circuits connected to more than one electrical source may be required to have overcurrent protection devices (OCPDs) located so as to provide overcurrent protection from all sources per 690.9(A). Fuses (when used) shall be installed as part of a finger safe fuse holder. Where source circuit OCPD is not required, please put N/A in 11A or 11B as applicable.

**Source circuit OCPD rating:**

**A. Combiner 1:**

(Total number of source circuits) – 1 = \_\_\_\_\_ (A)

(A) \* (Module I<sub>sc</sub>) \* 1.25 = \_\_\_\_\_ Amps (B)

Modules max OCPD rating (from module nameplate) = \_\_\_\_\_ Amps (C)

If (B) > (C), source circuit OCPD is required at the combiner to protect paralleled source circuits

**Source circuit OCPD size** \_\_\_\_\_ Amps

**B. Combiner 2 (If unused, circle N/A):** N/A

(Total number of source circuits) – 1 = \_\_\_\_\_ (A)

(A) \* (Module I<sub>sc</sub>) \* 1.25 = \_\_\_\_\_ Amps (B)

Modules max OCPD rating (from module nameplate) = \_\_\_\_\_ Amps (C)

If (B) > (C), source circuit OCPD is required at the combiner to protect paralleled source circuits

**Source circuit OCPD size** \_\_\_\_\_ Amps



**Central/String Inverter Systems for One and Two Family Dwellings**

**12) Sizing PV Output Circuit Conductors** – If a Combiner box will NOT be used [STEP #11], proceed to STEP #13. Use the LARGER minimum conductor ampacity from **Method A** or **Method B** when determining required conductor size, for both combiners 1 and 2 (when applicable).

**Combiner 1:**

**Method A:**

Minimum conductor ampacity: Maximum source circuit current [STEP#9] \_\_\_\_\_ × 1.25 × Number of parallel source circuits (STEP#5) \_\_\_\_\_ = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_ Raceway height above the roof: \_\_ inches (N/A if inapplicable)

C<sub>F</sub> = \_\_\_\_\_ C<sub>T</sub> = \_\_\_\_\_

Minimum conductor ampacity: Maximum circuit current [STEP#9] \_\_\_\_\_ × Number of parallel source circuits (STEP#5) \_\_\_\_\_ / (C<sub>F</sub> × C<sub>T</sub>) = \_\_\_\_\_ Amps

Using the greater current as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify output circuit conductor size (using 90°C-rated copper insulated conductors). The minimum conductor ampacity calculated from **Method A** or **Method B** shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

**Minimum Output Circuit Conductor Size \_\_\_\_\_AWG**

**Combiner 2 (If unused, circle N/A):** N/A

**Method A:**

Minimum conductor ampacity: Maximum source circuit current [STEP#9] \_\_\_\_\_ × 1.25 × Number of parallel source circuits (STEP#5) \_\_\_\_\_ = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_ Raceway height above the roof: \_\_ inches (N/A if inapplicable)

C<sub>F</sub> = \_\_\_\_\_ C<sub>T</sub> = \_\_\_\_\_

Minimum conductor ampacity: Maximum circuit current [STEP#9] \_\_\_\_\_ × Number of parallel source circuits (STEP#5) \_\_\_\_\_ / (C<sub>F</sub> × C<sub>T</sub>) = \_\_\_\_\_ Amps

Using the greater current as calculated in **Method A** or **Method B**, use 310.15(B)(16) to identify output circuit conductor size (using 90°C-rated copper insulated conductors). The minimum conductor ampacity calculated from **Method A** or **Method B** shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

**Minimum Output Circuit Conductor Size \_\_\_\_\_AWG**

**13) Inverter DC Disconnect** (The dc disconnect shall be grouped with the inverter and inverter ac disconnect)

**Does the inverter have an integrated dc disconnect? Yes / No**

If **yes**, proceed to STEP #14.

If **No**, the external dc disconnect to be installed is rated for \_\_\_\_\_ Amps (dc) and \_\_\_\_\_ Volts (dc)

The dc disconnect rating must be greater than or equal to the Max Output Circuit Current [STEP#12 - Method A] or Max Source Circuit Current [STEP #10 - Method A].



**Central/String Inverter Systems for One and Two Family Dwellings**

**14) Inverter information:**

Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Max. Continuous AC Output Current Rating: \_\_\_\_\_ Amps  
Maximum Inverter DC Input Current Rating: \_\_\_\_\_ Amps

Max Source Circuit Current (STEP#9) \_\_\_\_\_ Amps × Number of parallel source circuits (STEP#5) \_\_\_\_\_ = \_\_\_\_\_ Amps  
Calculated current from the line above (\_\_\_\_\_ Amps) ≤ Max. Inverter Short Circuit Current Rating (\_\_\_\_\_ Amps)

Max. Inverter Short Circuit Current Rating = 1.5 (per UL 1741 testing standard) × Max. Inverter DC Input Current Rating, if max short circuit current rating is not available from manufacturer.

Integrated DC Arc-Fault Circuit Protection? Yes / No (If “No” is selected, provide arc-fault protection per 690.11)

**AC Information:**

**15) Sizing Inverter Output Circuit Conductors and OCPD:** Use the LARGER conductor ampacity from **Method A** or **Method B** when determining conductor size. Use **Method A** to determine **Inverter Output OCPD rating**.

**Method A:**

Minimum conductor ampacity: Max AC Output Current Rating [STEP#14] \_\_\_\_\_ × 1.25 = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_\_\_\_ Raceway height above the roof: \_\_\_\_\_ inches

$C_F = \text{_____}$   $C_F$  is the conduit fill coefficient (refer to Table 310.15 (B)(3)(a))

$C_T = \text{_____}$   $C_T$  is the coefficient dependent on the highest continuous ambient temperature (refer to Table 310.15(B)(2)(a) ) and raceway height above roof (refer to Table 310.15(B)(3)(c) if applicable)

Minimum conductor ampacity: Maximum ac output current rating [STEP#14] \_\_\_\_\_ / ( $C_F \times C_T$ ) = \_\_\_\_\_ Amps

Minimum Conductor Size: \_\_\_\_\_ AWG

Using the greater current as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify ac circuit conductor size. The minimum conductor ampacity shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

Size the inverter output OCPD based on the value calculated in **Method A**. Where the figure is between two standard values of fuse/breaker sizes (see 240.6(A)), the next higher size may be used (see 240.4(B)). The OCPD’s rating may not exceed the conductor ampacity or the inverter manufacturer’s max OCPD rating for the inverter.

Inverter Output Max OCPD rating = \_\_\_\_\_ Amps



**Central/String Inverter Systems for One and Two Family Dwellings**

**16) Point of Connection to Utility:** One of the following methods of interconnection must be utilized.

**A. Supply Side Connection: Yes / No**

Check with your local jurisdiction to determine if this connection is allowed.

Supply side connections shall only be permitted where the service panel is listed for the purpose. The sum of the ratings of all overcurrent devices (STEP #15 or S22) connected to power production sources shall not exceed the rating of the service. The connection shall not compromise listing or integrity of any equipment.

**B. Load Side Connection: Yes / No**

**Is the PV OCPD positioned at the opposite end from input feeder location or main OCPD location? Yes / No**

(If No to the statement above, the sum of OCPD(s) supplying the panel cannot exceed 100% of the busbar rating; Circle 100% as the multiplier in calculation. Otherwise, circle 120% and use that as the multiplier)

**Per 705.12(D)(2)(3): [Inverter output OCPD size [STEP #15 or S22] + Main OCPD Size] ≤ [Bus size × (100% or 120%)]**

Maximum Combined Supply OCPDs Based on Busbar Rating (Amps) per CEC 705.12(D)(2)(3)									
Busbar Rating	100	125	125	200	200	200	225	225	225
Main OCPD	100	100	125	150	175	200	175	200	225
Max Combined PV System OCPD(s) at 120% of Busbar Rating	20	50	25	60*	60*	40	60*	60*	45
Max Combined PV System OCPD(s) at 100% of Busbar Rating	0	25	0	50	25	0	50	25	0

\*This value has been lowered to 60A from the calculated value to reflect 10kW ac size maximum.

All upstream panelboard busbar ratings must also comply with 705.12(D)(2)(3). If the main breaker is reduced, a load calculation per Article 220 must accompany the Standard Plans to show that the reduction is allowed.

**17) Per Section 690.53, a permanent label for the dc power source shall be installed at the PV dc disconnecting means that shall indicate the following:**

(a) Rated maximum power-point current ( $I_{mpp}$  from the module nameplate):

$I_{mpp}$  \_\_\_\_\_ × {1 (one source circuit) OR \_\_\_\_\_ (# source circuits in parallel [STEP#5])} \_\_\_\_\_ Amps

(b) Rated maximum power-point voltage ( $V_{mpp}$  from the module nameplate):

$V_{mpp}$  \_\_\_\_\_ × \_\_\_\_\_ {Max # of modules per source circuit [STEP#5]} \_\_\_\_\_ Volts

(c) Short circuit current of the PV system (= STEP#9, if no strings are combined prior to inverter)

Maximum source circuit current (STEP#9) \_\_\_\_\_ × \_\_\_\_\_ (Number of strings) \_\_\_\_\_ Amps

(d) Maximum system voltage [STEP#7 or #8 for systems with dc/dc converters]

[For systems with dc/dc converters, this label's maximum system voltage value shall be \_\_\_\_\_ Volts the larger of the following: the lowest value of the inverter's input voltage range OR the value calculated in STEP#8.]

If using dc/dc converters in series (fixed source circuit voltage) with or without an input voltage-regulating inverter, the value for (a) shall be the value for (c), and (b) shall not be applicable. If using dc/dc converters in parallel (fixed unit voltage), the value for (b) shall be the value for (d), and (a) shall not be applicable.

**18) Per Section 690.54, a permanent label shall be installed at an accessible location at the PV ac disconnecting means that shall indicate the following:**

(a) Rated ac output current:

AC Output Inverter 1 [STEP#14] \_\_\_\_\_ Amps

AC Output Inverter 2 [If Applicable] \_\_\_\_\_ Amps

Rated ac output current (sum of above values): \_\_\_\_\_ Amps

(b) Nominal operating ac voltage: \_\_\_\_\_ Volts



**Central/String Inverter Systems for One and Two Family Dwellings**

**19) Rapid Shutdown**

The rapid shutdown initiation device shall be labeled according to CEC 690.56(C), and its location shall be shown on the site plan drawing. The rapid shutdown initiation device may be the inverter output or input circuits' disconnecting means, the service main disconnect, or a separate device as approved by the AHJ. The disconnecting means shall be identified for the purpose, suitable for their environment, and listed as a disconnecting means. A single rapid shutdown initiation device shall operate all disconnecting means necessary to control conductors in compliance with CEC 690.12.

Note: Check with the AHJ regarding approval where field verification of reduction of voltage within the time required by CEC 690.12 is performed.

Rapid shutdown shall be provided as required by CEC 690.12 with one of the following methods (Select one):

- The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. A remotely-controlled AC disconnecting means is required immediately adjacent to or as close as practicable to the inverters, and located within 10 feet of the array.
- The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- Remotely-controlled DC disconnecting means are located within 10 feet of the PV array and DC input of the inverter(s), and the locations of the disconnecting means are such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- Remotely-controlled DC disconnecting means is located within 10 feet of the array at the DC input of inverter(s) connected to a module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter. Reduction of the voltage for the DC-DC converter output and the inverter output within the time required by CEC 690.12 shall be verified in the field, or the DC-DC converter output and the inverter output are listed to UL 1741 with rapid shutdown capability.
- A UL 1741-listed and identified inverter(s) with input and output rapid shutdown capability supplying module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter.

- A UL 1741-listed rapid shutdown system:

Manufacturer: \_\_\_\_\_

Testing Agency Name: \_\_\_\_\_

System Model Number: \_\_\_\_\_

System Components: \_\_\_\_\_



**Central/String Inverter Systems for One and Two Family Dwellings**

**20) Grounding and Bonding:**

Check one of the boxes for whether system is grounded or ungrounded:  **GROUND**ED (SEE A & B)

**UNGROUND**ED (SEE A & C)

**A. All Systems:**

Modules and racking must be bonded by a method listed to the UL 2703 standard and recognized by the respective equipment manufacturers. Bonding method is subject to AHJ approval. DC and AC equipment grounding conductor (EGC) shall be sized based on source and output circuit conductors per 690.45 using Table 250.122. Where exposed to physical damage, it is required to be #6 AWG copper per 690.46. A DC EGC is required for both grounded and ungrounded systems. If an existing premises grounding electrode system is not present, a new grounding electrode system must be established per 250.53. The DC EGC leaving the array and the AC EGC must be contained within the same raceway or cable or otherwise run with the circuit conductors serving the array per 690.43(F), 690.43(A), and 250.134(B).

Where supplementary grounding electrodes are installed, a bonding jumper to the existing grounding electrode must be installed. Bonding jumpers must be sized to the larger grounding conductor that it is bonded to (CEC 250.58).

**B. Grounded Systems:**

The DC grounding electrode conductor (GEC) from the inverter terminal must be unbroken or irreversibly spliced and sized minimum #8 AWG copper per article 250.166. The DC GEC from the inverter terminal to the existing grounding electrode system must tie to the existing grounding electrode or be bonded to the existing AC GEC using an irreversible means, per 250.64(C)(1).

A combined DC GEC and AC EGC may be run from the inverter DC grounding terminal to the grounding busbar in the associated AC equipment. This combined grounding conductor must be sized to the larger of the GEC and EGC sizes, with the bonding requirements of EGCs and remaining continuous as a GEC, per 690.47(C)(3).

**C. Ungrounded Systems:**


A DC GEC shall not be required from the inverter DC grounding terminal to the building grounding electrode system. The EGC shall run from the inverter to the grounding busbar in the associated AC equipment, sized per 690.45, using Table 250.122. Ungrounded conductors must be identified per 210.5(C). White-finished conductors are not permitted.



## Central/String Inverter Systems for One and Two Family Dwellings

### Markings

CA Electrical Code (CEC) Articles 690 and 705 and CA Residential Code (CRC) Section R331 require the following labels or markings be installed at these components of the photovoltaic system:



Informational note: ANSI Z535.4 provides guidelines for the design of safety signs and labels for application to products. A phenolic plaque with contrasting colors between the text and background would meet the intent of the code for permanency. No type size is specified, but 20 point (3/8") should be considered the minimum.

CEC 705.12 requires a permanent plaque or directory denoting all electric power sources on or in the premises and the rapid shutdown initiation device.

# SOLAR PV STANDARD PLAN - COMPREHENSIVE

## Central/String Inverter Systems for One and Two Family Dwellings

△ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
5	INTERNAL INVERTER DC DISCONNECT: YES / NO
6	CENTRAL INVERTER
7	LOAD CENTER INSTALLED?: YES / NO
8	PV PRODUCTION METER INSTALLED?: YES / NO
9	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
10	CONNECT TO INVERTER #2 (USE LINE DIAGRAM 2)

\* Consult with your local AHJ and /or Utility

### SINGLE-LINE DIAGRAM #1 – NO STRINGS COMBINED PRIOR TO INVERTER


CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:  GROUNDED (INCLUDE GEC)  UNGROUNDED

REFER TO STEP 19 FOR RAPID SHUTDOWN DETAILS


FOR UNGROUNDED SYSTEMS:

- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT

- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.



IF DC/DC CONVERTERS ARE USED, CHECK THE BOX BELOW THE CORRESPONDING CONFIGURATION



PARALLEL DC/DC CONVERTERS ON ONE SOURCE CIRCUIT (FIXED UNIT VOLTAGE DC/DC CONVERTERS)

DC/DC CONVERTERS ARE ALL RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE

CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				

## Central/String Inverter Systems for One and Two Family Dwellings

△TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	COMBINER BOX (STEPS 11 & 12 REQUIRED)
5	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
6	INTERNAL INVERTER DC DISCONNECT: YES / NO
7	CENTRAL INVERTER
8	LOAD CENTER INSTALLED?: YES / NO
9	PV PRODUCTION METER INSTALLED?: YES / NO
10	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
11	CONNECT TO INVERTER #2 (USE LINE DIAGRAM 4)

\* Consult with your local AHJ and /or Utility

### SINGLE-LINE DIAGRAM #2 – COMBINING STRINGS PRIOR TO INVERTER


CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:  GROUNDED (INCLUDE GEC)  UNGROUNDED

REFER TO STEP 19 FOR RAPID SHUTDOWN DETAILS

FOR UNGROUNDED SYSTEMS:

- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT


- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.



COMBINER CONDUCTOR/CONDUIT SCHEDULE					
□TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A1	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/> EGC/GEC:				
B1	EGC/GEC:				
C	EGC/GEC:				
D	EGC/GEC:				
E	EGC/GEC:				

NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)					
□TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A2	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/> EGC/GEC:				
B2	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE



IF DC/DC CONVERTERS ARE USED, THEY ARE RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)



**Central/String Inverter Systems for One and Two Family Dwellings**

**Supplemental Calculation Sheets for Inverter #2:**

(Only include if no more than one additional inverter is used)

DC Information:

Module Manufacturer: _____		Model: _____
S2) Module $V_{oc}$ (from module nameplate): _____ Volts		S3) Module $I_{sc}$ (from module nameplate): _____ Amps
S4) Module dc output power under standard test conditions (STC) = _____ Watts (STC)		
<b>S5) DC Module Layout</b>		
Identify each source circuit (string) for inverter 2 shown on the roof plan with a Tag (e.g. A,B,C,...)	Number of modules per source circuit for inverter 2	Identify, by tag, which source circuits on the roof are to be paralleled (if none, put N/A)
		Combiner 1:
		Combiner 2:
Total number of source circuits for inverter 2: _____		
<b>S6) Are DC/DC Converters used?</b> Yes / No If "No," go to STEP#S7. If "Yes," enter info below.		
DC/DC Converter Model #:	_____	DC/DC Converter Max DC Input Voltage: _____ Volts
Max DC Output Current:	_____ Amps	Max DC Output Voltage: _____ Volts
Max # of DC/DC Converters in an Input Circuit:	_____	DC/DC Converter Max DC Input Power: _____ Watts
Number of modules per DC/DC Converter _____ × Module DC Power [STEP#S4] ( _____ Watts) = _____ Watts		
Calculated power from the equation above ( _____ Watts) ≤ DC/DC Converter Max DC Input Power ( _____ Watts)		
If DC/DC Convert input voltage is 80 volts or greater, provide listed Arc-Fault Circuit protection (CEC 690.11).		
<b>S7) Maximum System DC Voltage</b> – Required for all systems		
Max system dc voltage shall not exceed 600 volts, inverter manufacturer's max input voltage rating (if dc/dc converters are not used) _____ volts, or dc/dc converter max dc input voltage rating (if applicable) _____ volts.		
If open-circuit voltage ( $V_{oc}$ from STEP#S2) temperature coefficients ( $\beta$ or $\epsilon$ ) are provided by module manufacturer, use the calculation in <b>Method 1</b> . If $V_{oc}$ temperature coefficient is not provided by module manufacturer, use the calculation in <b>Method 2</b> .		
<b>Module Count:</b> equal to maximum number of modules in ANY source circuit [STEP#S5] for systems without dc/dc converters OR equal to number of modules per dc/dc converter [STEP#S6] for systems with dc/dc converters)		
<b>Method 1:</b>		
$V_{oc}$ temperature coefficient ( $\beta$ )= _____ %/°C		
Module Count per source circuit _____ × { $V_{oc} + [(T_L-25) \times (\beta \times V_{oc})/100]$ } = _____ Volts		
If module manufacturer provides a voltage temperature coefficient ( $\epsilon$ ) in mV/°C, use the formula below.		
$V_{oc}$ temperature coefficient ( $\epsilon$ )= _____ mV/°C		
Module Count per source circuit _____ × { $V_{oc} + [(T_L-25) \times (\epsilon/1000)]$ } = _____ Volts		
<b>Method 2:</b>		
Module Count per source circuit _____ × $V_{oc}$ _____ × $K_T$ = _____ Volts,		
Where $K_T$ = _____ is a correction factor for ambient temperatures below 25°C. See Table 690.7.		

**Central/String Inverter Systems for One and Two Family Dwellings**

**S8) Maximum System DC Voltage from DC/DC Converters to Inverter** – Only required if “Yes” in STEP#S6

Maximum system dc voltage shall not exceed 600 volts or inverter manufacturer’s maximum input voltage rating. If using dc/dc converters with fixed source circuit voltage (connected in series), provide the calculation in **Method 1**. If using dc/dc converters connected in series with an inverter that regulates input dc voltage, provide the calculation in **Method 2**. If using dc/dc converters with fixed unit voltage (connected in parallel), provide the calculation in **Method 3**.

**Method 1:**

Max # of dc/dc converters in a source circuit [STEP#S6] \_\_\_\_\_ × Max dc output voltage [STEP#S6] \_\_\_\_\_ Volts  
 = Max system dc voltage \_\_\_\_\_ Volts

If Max system dc voltage \_\_\_\_\_ > inverter input voltage rating (\_\_\_\_ Volts) OR 600 Volts, the number of DC/DC converters in the source circuit used for the Method 1 calculation must be reduced to comply with code.

**Method 2:**

Inverter max input voltage \_\_\_\_\_ Volts = Max system dc voltage \_\_\_\_\_ Volts

If Max system dc voltage \_\_\_\_\_ > 600 Volts, the inverter used for the Method 2 calculation must be changed to comply with code.

**Method 3:**

Max dc output voltage [STEP#S6] \_\_\_\_\_ = Max system dc voltage \_\_\_\_\_ Volts

If Max system dc voltage \_\_\_\_\_ > inverter input voltage rating (\_\_\_\_ Volts) OR 600 Volts, the dc/dc converters or inverter used for the Method 3 calculation must be changed to comply with code.

**S9) Maximum Source Circuit Current** – If dc/dc converters are used, use 9(A). If not, use 9(B).

Calculate the maximum dc short circuit current per source circuit to allow for peak sunlight conditions:

**A. Largest number of dc/dc converters run in parallel on one source circuit:** \_\_\_\_\_ (= 1 if not run in parallel)

Max DC Output Current [STEP#S6] \_\_\_\_\_ × dc/dc converters in parallel \_\_\_\_\_ = Maximum Circuit Current \_\_\_\_\_ Amps

**B. Module I<sub>sc</sub> [STEP#S3] \_\_\_\_\_ × 1.25 = Maximum Circuit Current \_\_\_\_\_ Amps**

**S10) Sizing PV Source Circuit Conductors** – Use the LARGER minimum conductor ampacity from **Method A** or **Method B** when determining required conductor size.

**Method A:**

Minimum conductor ampacity: Maximum source circuit current [STEP#S9] \_\_\_\_\_ × 1.25 = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_\_\_\_ Raceway height above the roof: \_\_\_\_\_ inches

C<sub>F</sub> = \_\_\_\_\_ C<sub>F</sub> is the conduit fill coefficient (refer to Table 310.15 (B)(3)(a))

C<sub>T</sub> = \_\_\_\_\_ C<sub>T</sub> is the coefficient dependent on the highest continuous ambient temperature (refer to Table 310.15(B)(2)(a) ) and raceway height above roof (refer to Table 310.15(B)(3)(c) if applicable)

Minimum conductor ampacity: Maximum source circuit current [STEP#S9] \_\_\_\_\_ / (C<sub>F</sub> × C<sub>T</sub>) = \_\_\_\_\_ Amps

Using the greater current as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify source circuit conductor size (using copper 90°C-rated insulated conductors). The minimum conductor ampacity calculated from **Method A** or **Method B** shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

**Minimum Source Circuit Conductor Size \_\_\_\_\_ AWG**

(For ungrounded systems, exposed source conductors must be listed “PV Wire,” NOT USE-2, per 2013 CEC 690.35(D))



**Central/String Inverter Systems for One and Two Family Dwellings**

**S11) Are PV source circuits combined prior to the inverter? Yes / No**

**If No**, use Single Line Diagram 3 and proceed to **STEP#S13**.

**If Yes, Is the PV source circuit combined on the roof? Yes / No**

**If No**, use Single Line Diagram 4.

**If Yes**, provide a load break disconnecting means rated for the load in the combiner or within 6ft of the combiner (CEC 690.15(C)), and use single line diagram 4.

**If the source circuit voltage to combiner is 80 volts or greater, provide listed Arc-Fault Circuit protection (CEC 690.11).**

Source circuits and output circuits connected to more than one electrical source may be required to have overcurrent protection devices (OCPDs) located so as to provide overcurrent protection from all sources per 690.9(A). Fuses (when used) shall be installed as part of a finger safe fuse holder. Where source circuit OCPD is not required, please put N/A in S11A or S11B as applicable.

**Source circuit OCPD rating:**

**A. Combiner 1:**

(Total number of source circuits) – 1 = \_\_\_\_\_ **(A)**

**(A)** \* (Module  $I_{sc}$ ) \* 1.25 = \_\_\_\_\_ Amps **(B)**

Modules max OCPD rating (from module nameplate) = \_\_\_\_\_ Amps **(C)**

If **(B)** > **(C)**, source circuit OCPD is required at the combiner to protect paralleled source circuits

**Source circuit OCPD size** \_\_\_\_\_ Amps

**B. Combiner 2 (If unused, circle N/A):**      **N/A**

(Total number of source circuits) – 1 = \_\_\_\_\_ **(A)**

**(A)** \* (Module  $I_{sc}$ ) \* 1.25 = \_\_\_\_\_ Amps **(B)**

Modules max OCPD rating (from module nameplate) = \_\_\_\_\_ Amps **(C)**

If **(B)** > **(C)**, source circuit OCPD is required at the combiner to protect paralleled source circuits

**Source circuit OCPD size** \_\_\_\_\_ Amps



**Central/String Inverter Systems for One and Two Family Dwellings**

**S12) Sizing PV Output Circuit Conductors** – If a Combiner box will NOT be used [STEP#S11], proceed to STEP#S13. Use the LARGER minimum conductor ampacity from **Method A** or **Method B** when determining required conductor size, for both combiners 1 and 2 (when applicable).

**Combiner 1:**

**Method A:**

Minimum conductor ampacity: Maximum source circuit current [STEP#S9] \_\_\_\_\_ × 1.25 × Number of parallel source circuits (STEP#S5) \_\_\_\_\_ = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_ Raceway height above the roof: \_\_ inches (N/A if inapplicable)

C<sub>F</sub> = \_\_\_\_ C<sub>T</sub> = \_\_\_\_

Minimum conductor ampacity: Maximum circuit current [STEP#S9] \_\_\_\_\_ × Number of parallel source circuits (STEP#S5) \_\_\_\_\_ / (C<sub>F</sub> × C<sub>T</sub>) = \_\_\_\_\_ Amps

Using the greater current as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify output circuit conductor size (using 90°C-rated copper insulated conductors). The minimum conductor ampacity calculated from **Method A** or **Method B** shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

**Minimum Output Circuit Conductor Size \_\_\_\_\_ AWG**

**Combiner 2** (If unused, circle N/A): N/A

**Method A:**

Minimum conductor ampacity: Maximum source circuit current [STEP#S9] \_\_\_\_\_ × 1.25 × Number of parallel source circuits (STEP#S5) \_\_\_\_\_ = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_ Raceway height above the roof: \_\_ inches (N/A if inapplicable)

C<sub>F</sub> = \_\_\_\_ C<sub>T</sub> = \_\_\_\_

Minimum conductor ampacity: Maximum circuit current [STEP#S9] \_\_\_\_\_ × Number of parallel source circuits (STEP#S5) \_\_\_\_\_ / (C<sub>F</sub> × C<sub>T</sub>) = \_\_\_\_\_ Amps

Using the greater current as calculated in **Method A** or **Method B**, use 310.15(B)(16) to identify output circuit conductor size (using 90°C-rated copper insulated conductors). The minimum conductor ampacity calculated from **Method A** or **Method B** shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

**Minimum Output Circuit Conductor Size \_\_\_\_\_ AWG**

**S13) Inverter DC Disconnect** (The dc disconnect shall be grouped with the inverter and inverter ac disconnect)

**Does the inverter have an integrated dc disconnect? Yes / No**

If **yes**, proceed to STEP#S14.

If **no**, the external dc disconnect to be installed is rated for \_\_\_\_\_ Amps (dc) and \_\_\_\_\_ Volts (dc)

The dc disconnect rating must be greater than or equal to the Max Output Circuit Current [STEP#S12 – Method A] or Max Source Circuit Current [STEP #S10 - Method A].



**Central/String Inverter Systems for One and Two Family Dwellings**

**AC Information:**

**S14) Inverter information:**

Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Max. Continuous AC Output Current Rating: \_\_\_\_\_ Amps  
 Maximum Inverter DC Input Current Rating: \_\_\_\_\_ Amps

Max Source Circuit Current (STEP#S9) \_\_\_\_\_ Amps × Number of parallel source circuits (STEP#S5) \_\_\_\_\_ = \_\_\_\_\_ Amps  
 Calculated current from the line above (\_\_\_\_\_ Amps) ≤ Max. Inverter Short Circuit Current Rating (\_\_\_\_\_ Amps)

Max. Inverter Short Circuit Current Rating = 1.5 (per UL 1741 testing standard) × Max. Inverter DC Input Current Rating, if max short circuit current rating is not available from manufacturer.

**Integrated DC Arc-Fault Circuit Protection? Yes / No** (If “No” is selected, provide arc-fault protection per 690.11)

**S15) Sizing Inverter Output Circuit Conductors and OCPD:** Use the LARGER conductor ampacity from **Method A** or **Method B** when determining conductor size. Use **Method A** to determine **Inverter Output OCPD rating**.

**Method A:**

Minimum conductor ampacity: Max AC Output Current Rating [STEP#S14] × 1.25 = \_\_\_\_\_ Amps

**Method B:**

# of current-carrying conductors in raceway: \_\_\_\_\_ Raceway height above the roof: \_\_\_\_\_ inches

$C_f = \underline{\hspace{2cm}}$   $C_f$  is the conduit fill coefficient (refer to Table 310.15 (B)(3)(a))

$C_T = \underline{\hspace{2cm}}$   $C_T$  is the coefficient dependent on the highest continuous ambient temperature (refer to Table 310.15(B)(2)(a) ) and raceway height above roof (refer to Table 310.15(B)(3)(c) if applicable)

Minimum conductor ampacity: Maximum ac output current rating [STEP#S14] \_\_\_\_\_ / ( $C_f \times C_T$ ) = \_\_\_\_\_ Amps

Minimum Conductor Size: \_\_\_\_\_ AWG

Using the greater current as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify ac circuit conductor size. The minimum conductor ampacity shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

Size the inverter output OCPD based on the value calculated in **Method A**. Where the figure is between two standard values of fuse/breaker sizes (see 240.6(A)), the next higher size may be used (see 240.4(B)). The OCPD’s rating may not exceed the conductor ampacity or the inverter manufacturer’s max OCPD rating for the inverter.

Inverter Output Max OCPD rating = \_\_\_\_\_ Amps

**S16) Per Section 690.53, a permanent label for the dc power source shall be installed at the PV dc disconnecting means that shall indicate the following:**

(a) Rated maximum power-point current ( $I_{mpp}$  from the module nameplate):

$I_{mpp} \underline{\hspace{2cm}} \times \{1 \text{ (one source circuit) OR } \underline{\hspace{2cm}} \text{ (# source circuits in parallel [STEP#S5])}\} \underline{\hspace{2cm}} \text{ Amps}$

(b) Rated maximum power-point voltage ( $V_{mpp}$  from the module nameplate):

$V_{mpp} \underline{\hspace{2cm}} \times \underline{\hspace{2cm}} \{ \text{Max \# of modules per source circuit [STEP#S5]} \} \underline{\hspace{2cm}} \text{ Volts}$

(c) Short circuit current of the PV system (= STEP#S9, if no strings are combined prior to inverter)

Maximum source circuit current (STEP#S9) \_\_\_\_\_ × \_\_\_\_\_ (Number of strings) \_\_\_\_\_ Amps

(d) Maximum system voltage [STEP#S7 or #S8 for systems with dc/dc converters]

[For systems with dc/dc converters, this label’s maximum system voltage value shall \_\_\_\_\_ Volts

be the larger of the following: the lowest value of the inverter’s input voltage range

**OR** the value calculated in STEP#S8.]

(S17 and S18 reserved for future)





**Central/String Inverter Systems for One and Two Family Dwellings**

**S19) Rapid Shutdown**

The rapid shutdown initiation device shall be labeled according to CEC 690.56(C), and its location shall be shown on the site plan drawing. The rapid shutdown initiation device may be the inverter output or input circuits' disconnecting means, the service main disconnect, or a separate device as approved by the AHJ. The disconnecting means shall be identified for the purpose, suitable for their environment, and listed as a disconnecting means. A single rapid shutdown initiation device shall operate all disconnecting means necessary to control conductors in compliance with CEC 690.12.

Note: Check with the AHJ regarding approval where field verification of reduction of voltage within the time required by CEC 690.12 is performed.

Rapid shutdown shall be provided as required by CEC 690.12 with one of the following methods (Select one):

- The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. A remotely-controlled AC disconnecting means is required immediately adjacent to or as close as practicable to the inverters, and located within 10 feet of the array.
- The inverter(s) is within 10 feet of the array, and the location of the inverter is such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- Remotely-controlled DC disconnecting means are located within 10 feet of the PV array and DC input of the inverter(s), and the locations of the disconnecting means are such that uncontrolled PV system conductors are no greater than 5 feet of length within the building. Reduction of the voltage for the inverter output within the time required by CEC 690.12 shall be verified in the field, or the inverter output is listed to UL 1741 with rapid shutdown capability.
- Remotely-controlled DC disconnecting means is located within 10 feet of the array at the DC input of inverter(s) connected to a module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter. Reduction of the voltage for the DC-DC converter output and the inverter output within the time required by CEC 690.12 shall be verified in the field, or the DC-DC converter output and the inverter output are listed to UL 1741 with rapid shutdown capability.
- A UL 1741-listed and identified inverter(s) with input and output rapid shutdown capability supplying module level DC-DC converter circuit where the DC-DC converter circuit meets the requirements for controlled conductors when disconnected from the inverter.

- A UL 1741-listed rapid shutdown system:

Manufacturer: \_\_\_\_\_

Testing Agency Name: \_\_\_\_\_

System Model Number: \_\_\_\_\_

System Components: \_\_\_\_\_



**Central/String Inverter Systems for One and Two Family Dwellings**

**S20) Grounding and Bonding:**

Check one of the boxes for whether system is grounded or ungrounded:  **GROUNDED (SEE A & B)**

**UNGROUNDED (SEE A & C)**

**A. All Systems:**

Modules and racking must be bonded by a method listed to the UL 2703 standard and recognized by the respective equipment manufacturers. Bonding method is subject to AHJ approval. DC and AC equipment grounding conductor (EGC) shall be sized based on source and output circuit conductors per 690.45 using Table 250.122. Where exposed to physical damage, it is required to be #6 AWG copper per 690.46. A DC EGC is required for both grounded and ungrounded systems. If an existing premises grounding electrode system is not present, a new grounding electrode system must be established per 250.53. The DC EGC leaving the array and the AC EGC must be contained within the same raceway or cable or otherwise run with the circuit conductors serving the array per 690.43(F), 690.43(A), and 250.134(B).

Where supplementary grounding electrodes are installed, a bonding jumper to the existing grounding electrode must be installed. Bonding jumpers must be sized to the larger grounding conductor that it is bonded to (CEC 250.58).

**B. Grounded Systems:**

The DC grounding electrode conductor (GEC) from the inverter terminal must be unbroken or irreversibly spliced and sized minimum #8 AWG copper per article 250.166. The DC GEC from the inverter terminal to the existing grounding electrode system must tie to the existing grounding electrode or be bonded to the existing AC GEC using an irreversible means, per 250.64(C)(1).

A combined DC GEC and AC EGC may be run from the inverter DC grounding terminal to the grounding busbar in the associated AC equipment. This combined grounding conductor must be sized to the larger of the GEC and EGC sizes, with the bonding requirements of EGCs and remaining continuous as a GEC, per 690.47(C)(3).

**C. Ungrounded Systems:**

A DC GEC shall not be required from the inverter DC grounding terminal to the building grounding electrode system. The EGC shall run from the inverter to the grounding busbar in the associated AC equipment, sized per 690.45, using Table 250.122. Ungrounded conductors must be identified per 210.5(C). White-finished conductors are not permitted.

**Central/String Inverter Systems for One and Two Family Dwellings**

**Load Center Calculations:**

**(Only include if a load center will be installed)**

**S21) Maximum output for each inverter:**

From supplemental calculation sheet used, list the calculated maximum ac output value [STEP#S14]:

**Inverter #1 Maximum ac output: \_\_\_\_\_ Amps**

**Inverter #2 Maximum ac output: \_\_\_\_\_ Amps**

**S22) Load Center Output:**

Calculate the sum of the maximum ac outputs from [STEP#S21].

**Total inverter currents connected to load center = \_\_\_\_\_ Amps**

Use the LARGER conductor ampacity from **Method A** or **Method B** when determining conductor size. Use **Method A** to determine **Inverter Output OCPD rating**.

**Method A:**

**Minimum conductor ampacity: Max AC Output Current Rating [STEP#S22] \_\_\_\_\_ x 1.25 = \_\_\_\_\_ Amps**

**Method B:**

**# of current-carrying conductors in raceway: \_\_\_\_\_ Raceway height above the roof: \_\_\_\_\_ inches**

**$C_F = \text{_____}$   $C_F$  is the conduit fill coefficient (refer to Table 310.15 (B)(3)(a))**

**$C_T = \text{_____}$   $C_T$  is the coefficient dependent on the highest continuous ambient temperature (refer to Table 310.15(B)(2)(a) ) and raceway height above roof (refer to Table 310.15(B)(3)(c) if applicable)**

**Minimum conductor ampacity: Maximum ac output current rating [STEP#S22] \_\_\_\_\_ / ( $C_F \times C_T$ ) = \_\_\_\_\_ Amps**

**Minimum Conductor Size: \_\_\_\_\_ AWG**

Using the greater ampacity as calculated in **Method A** or **Method B**, use Table 310.15(B)(16) to identify ac circuit conductor size. The conductor ampacity shall not exceed the ampacity of chosen conductor rated at the lowest temperature rating of any connected termination, conductor, or device (60°C or 75°C).

Size the OCPD based on the value calculated in **Method A**. Where the figure is between two standard values of fuse/breaker sizes (see 240.6(A)), the next higher size may be used provided the conductors are sufficiently sized.

**Overcurrent Protection Device: \_\_\_\_\_ Amps**

**Load center busbar rating: \_\_\_\_\_ Amps**

The sum of the ampere ratings of overcurrent devices in circuits supplying power to a busbar or conductor shall not exceed 120 percent of the rating of the busbar or conductor.

**Central/String Inverter Systems for One and Two Family Dwellings**



△ TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
5	INTERNAL INVERTER DC DISCONNECT: YES / NO
6	CENTRAL INVERTER
7	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
8	TO LOAD CENTER ON LINE DIAGRAM 1

\* Consult with your local AHJ and /or Utility

**SINGLE-LINE DIAGRAM #3 – ADDITIONAL INVERTER FOR DIAGRAM #1**

**INVERTER # 2**

CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:  GROUNDED (INCLUDE GEC)


REFER TO STEP S19 FOR RAPID SHUTDOWN DETAILS

UNGROUNDED


FOR UNGROUNDED SYSTEMS:

- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT


- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.



IF DC/DC CONVERTERS ARE USED, CHECK THE BOX BELOW THE CORRESPONDING CONFIGURATION



PARALLEL DC/DC CONVERTERS ON ONE SOURCE CIRCUIT (FIXED UNIT VOLTAGE DC/DC CONVERTERS)



DC/DC CONVERTERS ARE ALL RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE

**CONDUCTOR/CONDUIT SCHEDULE**

<input type="checkbox"/> TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/> EGC/GEC:				
B	EGC/GEC:				
C	EGC/GEC:				

**Central/String Inverter Systems for One and Two Family Dwellings**



△TAG	DESCRIPTION
1	SOLAR PV MODULE / STRING
2	DC/DC CONVERTERS INSTALLED? YES / NO (IF YES, STEPS 6 & 8 REQUIRED)
3	SOURCE CIRCUIT JUNCTION BOX INSTALLED?: YES / NO
4	COMBINER BOX (STEPS 11 & 12 REQUIRED)
5	SEPARATE DC DISCONNECT INSTALLED?: YES / NO
6	INTERNAL INVERTER DC DISCONNECT: YES / NO
7	CENTRAL INVERTER
8	*SEPARATE AC DISCONNECT INSTALLED?: YES / NO
9	TO LOAD CENTER ON LINE DIAGRAM 3

\* Consult with your local AHJ and /or Utility

**SINGLE-LINE DIAGRAM #4 – ADDITIONAL INVERTER FOR DIAGRAM #2**

**INVERTER # 2**


CHECK A BOX FOR WHETHER SYSTEM IS GROUNDED OR UNGROUNDED:  GROUNDED (INCLUDE GEC)  UNGROUNDED

REFER TO STEP S19 FOR RAPID SHUTDOWN DETAILS

FOR UNGROUNDED SYSTEMS:

- DC OCPD MUST DISCONNECT BOTH CONDUCTORS OF EACH SOURCE CIRCUIT


- UNGROUNDED CONDUCTORS MUST BE IDENTIFIED PER 210.5(C). WHITE-FINISHED CONDUCTORS ARE NOT PERMITTED.



COMBINER CONDUCTOR/CONDUIT SCHEDULE					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A1	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B1					
	EGC/GEC:				
C					
	EGC/GEC:				
D					
	EGC/GEC:				


NON-COMBINED STRINGS CONDUCTOR/CONDUIT SCHEDULE (IF APPLICABLE)					
□ TAG	DESCRIPTION AND CONDUCTOR TYPE	CONDUCTOR SIZE	NUMBER OF CONDUCTORS	CONDUIT/CABLE TYPE	CONDUIT SIZE
A2	USE-2 <input type="checkbox"/> OR PV-WIRE <input type="checkbox"/>				
	EGC/GEC:				
B2					
	EGC/GEC:				

ENTER "N/A" WHERE SUITABLE FOR WHEN NOT USING CONDUIT OR CABLE AS PERMITTED BY CODE



IF DC/DC CONVERTERS ARE USED, THEY ARE RUN IN SERIES (FIXED SOURCE CIRCUIT VOLTAGE DC/DC CONVERTERS)

**Central/String Inverter Systems for One and Two Family Dwellings**



Items required: roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means, roof access points, and rapid shutdown initiation device.