

REQUEST FOR MODIFICATION OF BUILDING ORDINANCES

UNDER AUTHORITY OF L.A.M.C. SECTION 98.0403

PERMIT APP. #:	DATE:						
JOB ADDRESS:							
Tract:	Block:						
	Lot:						
Owner:	Petitioner:						
Address:	Address:						
City State Zip Phone	City State Zip Phone						
REQUEST (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSARY)	CODE SECTIONS: L.A.M.C. 705.8,705.12						
To allow a water curtain (fire sprinkler system) in-lieu of providing rated fire assemblies in openings in an exterior wall within 10ft (not permitted for less than 3ft) of a property line, center line of a street, or open space for a basement or parking level on the ground floor serving a building with no fire sprinkler system thru-out. Opening protectives are not required where the building is protected throughout by an automatic sprinkler system and the exterior openings are protected by an approved water curtain per Section 705.12. JUSTIFICATION (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSARY)							
Owner/Petitioner Name (Print) (Signature)	Position						
FOR CITY DEPARTMENT'S L	ISE ONLY BELOW THIS LINE						
Concurrences required from the following Department(s) Image: Los Angeles Fire Department Print Name Image: Public Works Bureau of Engineering Print Name Image: Department of City Planning Print Name Image: Department of County Health Print Name Image: Other Image: Department of County Health Print Name	Sign						
DEPARTMENT ACTION Reviewed by: (Staff) (print) Sign Date GRANTED DENIED Action taken by: (Supervisor) (print) Sign Date							
NOTE: IN CASE OF DENIAL, SEE PAGE #2	OF THIS FORM FOR APPEAL PROCEDURES						
CONDITIONS OF APPROVAL (Continued on Pag	ye 2): For Cashiers Use Only (PROCESS ONLY WHEN FEES ARE VERIFIED)						
1. The maximum area of the openings at subject story level shall not exceed the values for protected openings set forth in Table 705.8.							
Research Fee (Total Hours Worked) = 2 X \$104.00 Subtotal	= 0.00 = 208.00 = 338.00 = 6.76 = 20.28 = 365.04						

Permit App #:

Job Address:

CONDITIONS OF APPROVAL	(Continued from Page 1)	ļ
-------------------------------	-------------------------	---

 Plumbing division approval is required prior to installation of sprinkler installation of sprinkler system.
 A minimum 18-inch deep draft stop shall be provided immediately adjacent to the protected opening as required by 4-13.3.4 of division 20 of the mechanical code.

CITY OF LOS ANGELES BOARD OF BUILDING AND SAFETY/DISABLED ACCESS COMMISSION APPEAL FORM

(Must be Attached to the Modification Request Form, Page 1)

AFFIDAVIT – LADBS BOARD OF BUI					NERS – RESOLUTION NO. 832-93				
I,	do state and swear as follows:								
 I, do state and swear as follows: (Print or Type Name of the Person Signing this Form) 1. The name and mailing address of the owner of the property (as defined in the resolution 832-93) at as shown on the appeal application (LADBS Com 31) are correct, and 									
2. The owner of the property as shown on the a	appeal a	pplication will be	e made a	aware of the app	peal and will receive a copy of the appeal.				
I declare under PENALTY OF PERJURY that the forgo	ing is tru	e and correct.							
Owner's Name(s)						_			
(Please Typ	e or Print			Please Type or Print					
Owner's Signature(s)				(Two Office	rs' Signatures Required for Corporations)				
Name of Corporation(Please Print Name	o of Corpor	ation		. <u>.</u>	(Please Type or Print)	_			
				00					
Dated this day of				20					
CALIFORNIA ALL-PURPOSE ACKNOWL	.EDGE	MENT		SIGN	NATURE(S) MUST BE NOTARIZED				
State of CALIFORNIA Co	ounty of			on		_			
before me.		, personal	lv appe	ared					
before me, Name, Title of Officer (e.g. Jane Doe,	Notary Pu	ublic)	.) «թթօ		Name(s) of Signer(s)	_,			
who proved to me on the basis of satisfactory evidence subscribed to the within instrument and acknowledged t in his/her/their authorized capacity(ies), and that by his/h person(s), or the entity upon behalf of which the person certify under PENALTY OF PERJURY under the law foregoing is true and correct.	to me tha her/their (s) acteo	at he/she/they e signature(s) on I, executed the i	xecuted the instr	thé same rument in ent. I					
WITNESS my hand and official seal.				Sign	ature				
					OF BUILDING AND SAFETY ALS COMMISSION				
Applicant's Name					Applicant's Title				
Signature					Date				
FEES					For Cashiers Use Only				
Board Fee (No. of Items)	х	\$130.00	_	0.00	(PROCESS ONLY WHEN FEES ARE VERIFIED))			
Inspection Fee (No of Insp.) =	× X	\$84.00	=						
Research Fee (Total Hours Worked) =		\$104.00	= _	0.00					
Subtotal			=	0.00					
Surcharge (One Stop)	Х	2%	= _	0.00					
Surcharge (Systems Development)	Х	6%	= _	0.00					
Total Fees			= _	0.00					
Fees verified by:									
Print and Sign									