



GREEN BUILDING CODE CORRECTION SHEET FOR ADDITIONS AND ALTERATIONS TO RESIDENTIAL BUILDINGS (2014 LAGBC)

Plan Check Submittal Date: _____
Plan Check / Permit Application Number: _____ / _____ - _____ - _____
Job Address: _____
Applicant: _____ Phone: _____
P.C. Engineer: _____ Phone: _____
E-mail: _____

INSTRUCTIONS FOR PROCEEDING WITH THE PLAN CHECK (PC) PROCESS:

1. **Review corrections marked on this Plan Check Correction Sheet**, the plans, and the calculation sheets.
2. Provide a written response or reference to details pursuant to the corrections. Location of any revisions on the plans shall be identified as part of your responses. Any of the forms requested by this document can be found on-line at <http://www.ladbs.org/LADBSWeb/green-bldg.jsf>
3. Phone or email the Plan Check engineer for a verification appointment after you have addressed the corrections. Verification of corrections is only done by appointment.
4. Bring the originally checked set of plans and calculations at the time of your appointment with this plan correction sheet.
5. **If you have any questions or need clarification on any plan check matters, please contact a plan check supervisor or call our Customer Hotline at (213) 202-3400.**

ADMINISTRATIVE

1. Complete and incorporate *Mandatory Requirements Checklist: Additions and Alterations to Residential Buildings*, Form GRN 9 (revised 07/01/2015), into the plans. (102.2)
2. In mixed occupancy buildings, each portion of a building shall comply with the specific green building measures applicable to each specific occupancy. Refer to non-residential correction sheet for non-residential portion. (302)

PLANNING AND DESIGN

3. The *Storm Water Pollution Control*, Form GRN 1, shall be incorporated into the plans. (4.106.2)

4. Construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering the building. Contour lines, elevation points, and/or slope arrows may be used to show compliance with this requirement. (4.106.3)
5. Plans shall identify the type of roofing, manufacturer, product, and color used. Incorporate the material specifications for the roofing product used and show that it meets the following minimum SRI value or both solar reflectance and thermal emittance values:
 - a. For roof slopes < 2:12: SRI value of at least 75 or both a 3-year solar reflectance of at least 0.63 and a thermal emittance of at least 0.75
 - b. For roof slopes ≥ 2:12: SRI value of at least 16 or both a 3-year solar reflectance of at least 0.20 and a thermal emittance of at least 0.75 (4.106.5)

WATER EFFICIENCY AND CONSERVATION

6. Add note to plans: "The flow rates for all new plumbing fixtures shall comply with the maximum flow rates specified in Section 4.303.1" (4.303.1)
7. Incorporate Form **GRN 16** into plans.
8. Document on drawings: "When a shower is served by more than one showerhead, the combined flow rate of all the showerheads and/or other outlets controlled by a single valve shall not exceed 2.0 gallons per minute at 80 psi, or the shower shall be designed to only allow one showerhead to be in operation at a time." (4.303.1.3.2)
9. For rehabilitated landscapes of 2,500sqft and new landscape areas of 500 square feet or more are subject to the 2015 Model Water Efficient Landscape Ordinance (MWELo). Refer to the MWELo supplemental correction sheet for additional comments. (4.304.1)
10. Show location of irrigation controller(s) on plans. Irrigation controller(s) shall be either weather- or soil-based under any of the following conditions:
 - a. Any newly-installed irrigation controller(s); or
 - b. On sites with 2,500 sq. ft. or more of cumulative irrigated landscape areas. (4.304.2)
11. Add note to plans: "For projects that include landscape work, the *Landscape Certification*, Form GRN 12, shall be completed prior to final inspection approval." (State Assembly Bill No. 1881)

MATERIAL CONSERVATION AND RESOURCE EFFICIENCY

12. Show or state on plans that annular spaces around pipes, electric cables, conduits, or other openings in the sole/bottom plates at exterior walls shall be protected against the passage of rodents by closing such openings with cement mortar, concrete masonry, or metal plates. Piping prone to corrosion shall be protected in accordance with Section 313.0 of the Los Angeles Plumbing Code. (4.406.1)
13. Provide flashing details for all new roof valleys, around new windows and doors, and at new chimney to roof intersections on the building plans. (4.407.3)
14. Add note to plans: "Materials delivered to the construction site shall be protected from rain or other sources of moisture." (4.407.4)

15. Construction waste shall be reduced by 50%. Indicate how construction waste will be handled:
 - a. City of Los Angeles certified hauler
 - b. Source separated on site (Incorporate waste management plan onto plans) (4.408.1)
16. Note on the drawings: "An Operation and Maintenance Manual including, at a minimum, the items listed in Section 4.410.1, shall be completed and placed in the building at the time of final inspection." Form GRN 6 (4.410.1)

ENVIRONMENTAL QUALITY

17. Plans shall state that the fireplace is direct-vent, sealed combustion type. Any installed woodstove or pellet stove shall comply with U.S. EPA Phase II emission limits where applicable. Incorporate manufacturer's specifications onto plans. (4.503.1)
18. Wood burning fireplaces and other wood burning devices are prohibited. (AQMD Rule 445)
19. Add note to plans: "All duct and other related air distribution component openings shall be covered with tape, plastic, or sheet metal until the final startup of the heating, cooling and ventilating equipment." (4.504.1)
20. Add note to plans: "Architectural paints and coatings, adhesives, caulks and sealants shall comply with the Volatile Organic Compound (VOC) limits listed in Tables 4.504.1- 4.504.3." (4.504.2.1-4.504.2.3)
21. The *VOCs and Formaldehyde Limits*, Form GRN 11, shall be incorporated into the plans.
22. Add the following notes to plans:
 - a. The *VOC Content Verification Checklist*, Form GRN 2, shall be completed and verified prior to final inspection approval. The manufacturer's specifications showing VOC content for all applicable products shall be readily available at the job site and be provided to the field inspector for verification. (4.504.2.4)

- b. All new carpet installed in the building interior shall meet the testing and product requirements of one of the following:
 - i. Carpet and Rug Institute's Green Label Plus Program
 - ii. California Department of Public Health's Specification 01350
 - iii. NSF/ANSI 140 at the Gold level
 - iv. Scientific Certifications Systems Indoor Advantage™ Gold (4.504.3)
- c. All new carpet cushion installed in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program. (4.504.3.1)
- d. 80% of the total area receiving resilient flooring shall comply with one or more of the following:
 - i. Certified as a CHPS Low-Emitting Material in the CHPS High Performance Products Database
 - ii. Certified under UL GREENGUARD Gold
 - iii. Certified under the Resilient Floor Covering Institute (RFCI) FloorScore program
 - iv. Meet the California Department of Public Health's Specification 01350 (4.504.4)
- e. New hardwood plywood, particle board, and medium density fiberboard composite wood products used in the interior or exterior of the building shall meet the formaldehyde limits listed in Table 4.504.5. (4.504.5)
- f. The *Formaldehyde Emissions Verification Checklist*, Form GRN 3, shall be completed prior to final inspection approval. The manufacturer's specifications showing formaldehyde content for all applicable wood products shall be readily available at the job site and be provided to the field inspector for verification. (4.504.5)
- g. Building materials with visible signs of water damage shall not be installed. Wall and floor framing shall not be enclosed until it is inspected and found to be satisfactory by the building inspector. (4.505.3)
- h. The heating and air-conditioning systems shall be sized and designed using ANSI/ACCA Manual J-2004, ANSI/ACCA 29-D-2009 or ASHRAE handbooks and have their equipment selected in accordance with ANSI/ACCA 36-S Manual S-2004. (4.507.2)
- 23. A 4-inch thick base of ½ inch or larger clean aggregate shall be provided for the proposed slab on grade construction. Show on details. (4.505.2.1)
- 24. A vapor barrier shall be provided in direct contact with concrete for the proposed slab on grade construction. Show on details. (4.505.2.1)
- 25. Show location of newly installed exhaust fans for bathrooms containing bathtubs, showers, or tub/shower combinations. Plans shall state that the bathroom exhaust fans comply with the following:
 - i. Fans shall be ENERGY STAR compliant and be ducted to terminate to the outside of the building.
 - ii. Fans, not functioning as a component of a whole house ventilation system, must be controlled by a humidity control. (4.506.1)

ADDITIONAL CORRECTIONS / COMMENTS

No.		Code Sec. No.
	When the building plans are complete, please make an appointment with your plan check reviewer. Bring the final set of plans along with this correction sheet and marked set for Green Building approval and permit clearance.	

No.		Code Sec. No.