

## REQUEST FOR MODIFICATION OF BUILDING ORDINANCES

UNDER AUTHORITY OF L.A.M.C. SECTION 98.0403

PERMIT APP. #:	DATE:					
JOB ADDRESS:						
Tract:	Block:					
	Lot:					
Owner:	Petitioner:					
Address:	Address:					
City State Zip Phone	City State Zip Phone					
REQUEST (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSARY)	CODE SECTIONS: N.E.C. 215.2					
Permission to apply a demand factor of 0.65 to a group of reefer receptacles and the associated transformer feeder(s).						
To this color to apply a domaina factor of close to a group of roo	ror rocoptacios and the accordated transformer rocaci (c).					
JUSTIFICATION (SUBMIT PLANS OR ADDITIONAL SHEETS AS NECESSAR'	Y)					
,	•					
Owner/Petitioner Name (Print) (Signature)	Position					
FOR CITY DEPARTMENT'S U	JSE ONLY BELOW THIS LINE					
Concurrences required from the following Department(s)	Approved Denied					
Los Angeles Fire Department Print Name						
Public Works Bureau of Engineering Print Name	Sign					
Department of City Planning Print Name	Sign					
Department of County Health Print Name	Sign					
Other Print Name	Sign					
DEPARTMENT ACTION Reviewed by: (Staff) (Print)	Sign Date					
GRANTED DENIED	Sign Date					
Action taken by: (Supervisor) (P						
NOTE: IN CASE OF DENIAL, SEE PAGE #2	OF THIS FORM FOR APPEAL PROCEDURES					
CONDITIONS OF APPROVAL (Continued on Page 2):  For Cashiers Use Only (PROCESS ONLY WHEN FEES ARE VERIFIED)						
1.Permision is granted to apply a demand factor of 0.65 to size the transformer and						
its feeder only. This demand factor shall not apply to the branch circu						
2. The power distribution transformer shall be periodically maintained	d and serviced.					
All such work shall be recorded and done by qualified personnel.						
FEES (DEPARTMENT USE ONLY)						
	= 0.00					
	= 0.00					
Research Fee (Total Hours Worked) = X \$104.00	= 0.00					
	= 0.00					
· · · · · · · · · · · · · · · · · · ·	= 0.00					
, · · · · · · · · · · · · · · · · · · ·						
Total Face	= 0.00					
Total Fees Fees verified by:	= 0.00					

Permit App #:	Job Address:

## **CONDITIONS OF APPROVAL (Continued from Page 1)**

- 3. If frequent tripping of an overcurrent device or abnormal temperature rise is noticed in conductors and transformer, the approval of this variance shall be considered void and the loads connected to the feeder and transformer shall be redesigned and Electrical Plan Check approval shall be obtained.
- 4. The transformer feeding the reefer outlet distribution board shall be equipped with an audible over temperature alarm, monitoring the fluid and coil temperatures. In case of an over temperature condition, the transformer secondary overcurrent protective device shall be de-energized. This overcurrent device shall not be re-energized until the transformer loading is below its rated capacity.
- 5. The distribution board feeder shall be constantly monitored with an approved device(s) for its actual demand use. If the demand reading results in a
- demand factor greater than 65%, the feeder breaker shall be de-energized. This breaker shall not be re-energized until the feeder demand is at or below 65%.
- 6. When maintaining liquid field transformers, the replaced fluid shall be of an approved, less or non-flammable liquid of the same or better dielectric strength. If the transformer lacks a cooling circulation pump, the insulating fluid shall have an equal or better temperature index as compared to the original insulating fluid. This transformer shall also comply with LAEC Section 450.28.

## CITY OF LOS ANGELES BOARD OF BUILDING AND SAFETY/DISABLED ACCESS COMMISSION APPEAL FORM

(Must be Attached to the Modification Request Form, Page 1)

AFFIDAVIT – LADBS BOARD OF B					ONERS – RESOLUTION NO. 832-93	
					ONLING - REGOLOTION NO. 002-90	
(Print or Type Name of the Person Signing this Form)	a	o state and sw	ear as tolic	ows:		
The name and mailing address of the owner of the property (as defined in the resolution 832-93) at as show the appeal application (LADBS Com 31) are correct, and						
<ol><li>The owner of the property as shown on the</li></ol>	e appeal a	application will be	e made awa	re of the ap	ppeal and will receive a copy of the appeal.	
I declare under PENALTY OF PERJURY that the for						
Owner's Name(s)(Please Type or Print)				(Please Type or Print)		
(Flease	Type or Filling	,	<b>/</b> 7			
Owner's Signature(s)(Ple	ease Sign)		(1	_ (Two Officers' Signatures Required for Corporations)		
Name of Corporation(Please Print N					(Please Type or Print)	
Dated this day of				20	· · · · · · · · · · · · · · · · · · ·	
CALIFORNIA ALL-PURPOSE ACKNOV					` '	
					1	
before me,	Na Natari F	, personal	lly appeare	ed	Name(s) of Signer(s)	
to the within instrument and acknowledged to me that authorized capacity(ies), and that by his/her/their sign	at he/she/tl nature(s) c	hey executed the on the instrument	e same in hi i in person(s	s/her/their ), or the en	scribed	
upon behalf of which the person(s) acted, executed t PERJURY under the laws of the State of Californ						
WITNESS my hand and official seal.				Sig	gnature	
As a covered entity under Title II of the Americans v	As a covered entity under Title II of the Americans with Disabilities Act, the City of Los Angeles does not discriminate on the basis of disability and, upon request, v					
					rograms, services and activities.  OF BUILDING AND SAFETY	
					EALS COMMISSION	
Applicant's Name					Applicant's Title	
Signature					Date	
FEES (DEPARTMENT USE ONLY)				For Cashiers Use Only		
Board Fee(No. of Items)	1 X	\$130.00	=	0.00	(PROCESS ONLY WHEN FEES ARE VERIFIED)	
Inspection Fee (No of Insp.) =			=			
Research Fee (Total Hours Worked) =	Х	\$104.00	=	0.00		
Subtotal			=	0.00		
Development Services Center Surcharge	Χ	3%	=	0.00		
Systems Development Surcharge	Χ	6%	=	0.00		
Total Fees			=	0.00		
Fees verified by:						
Print and Sign						